



April 15, 2008

Mr. David Harper
DLH Plating, LLC
2800 Grand Avenue
Cleveland, Ohio 44104

Mr. Frank Nagorney
Grand Avenue Realty Company
2800 Grand Avenue
Cleveland, Ohio 44104

Re: Notice of Violation

Dear Mssrs. Harper & Nagorney:

This correspondence is to inform you that DLH Plating has been determined to have violations of the *Code of Regulations* of the Northeast Ohio Regional Sewer District (NEORSRD). Excursions of the regulations occurred for the failing to meet the requirements of the Administrative Order issued March 31, 2008. Specifically DLH Plating has failed to:

1. Dispose of all stored wastes at the facility in accordance with applicable regulations consistent with the requirement of the Ohio EPA and the Cleveland Fire Department. Copies of manifests and/or Bills of Lading shall be submitted to the NEORSRD immediately upon disposal.
2. Hire a qualified sewer cleaning company to plug and clean the sewer from the 100% manhole adjacent to the pump house in an upstream direction to the bulkhead manhole. The sewer plug shall be installed at the 100% manhole and all wastewater generated during the cleaning shall be captured and properly disposed. The NEORSRD shall be notified of the date and time this cleaning will take place 48 hours in advance. (Due by April 11, 2008)
3. Notify the NEORSRD of any open drains located in the facility. DLH/GARC shall seal/eliminate any open floor drains in the facility. (Due by April 4, 2008)


4. Eliminate any process or waste contamination on the floors and/or in any pits within the facility. (Due by April 11, 2008)
5. Hire an environmental consultant to investigate groundwater conditions using standard remedial investigation techniques at the site of DLH Plating. A scope of work shall be submitted to the NEORSO for approval. A report on the findings shall be forwarded to the NEORSO upon receipt. (Due to be initiated by April 11, 2008)

As a consequence, your company has 7 days from the date of this correspondence to respond to the Water Quality and Industrial Surveillance Section, in writing, about the remedial measures that will be taken to bring your discharge into full compliance with the *Code of Regulations*.

Any further violation of the regulations will be cause to escalate enforcement action against your company. Failure to respond within 7 days and/or failure to take corrective action to bring about compliance could forfeit your use of the public sewer system.

If you have any questions regarding any of these requirements, please contact me at (216) 641-6000 extension 2217 or at broski@neorsd.org.

Sincerely,



Scott C. Broski
Manager
Water Quality & Industrial Surveillance

cc: Frank Foley
Lawrence English
Company File